

**Leakage Area EN 14239**

System	W2 Exhaust
Test section	
Expected Leakage class	C
Test pressure	100 Pa
Max Leakage per m ²	0,060 l/(sm ²)

Leakage Area in section	3,958 m²
Max Leakage in section	0,24 l/s

Product	Pos. nr.	Calculation (mm)	Area (m ²)
kanal okrągły SR 125	W2-5	393*2396	0,941
anemostat KSU 150	W2-13	17671	0,018
kanal okrągły SR 125	W2-9	393*2283	0,897
anemostat KSU 100	W2-15	7854	0,008
kolano BU 125 90	W2-6	393*250	0,098
nypel NPU 125	W2-4	393*12	0,005
redukcja TCPU 125 100	W2-8	393*130 + 314*78	0,076
kanal okrągły SR 125	W2-7	393*683	0,268
nypel NPU 125	W2-10	393*12	0,005
sokół dachowy-125	W2-3	628*1000	0,628
kanal okrągły SR 200	W2-1	628*221	0,139
nypel NPU 200	W2-2	628*12	0,008
flex FD 125	W2-11	125*1262	0,15775
flex FD 100	W2-14	100*993	0,0993

0,25705